



EU - type Examination Certificate

This is to certify that the product listed below conforms to the requirements of the

Pressure Equipment Directive 2014/68/EU

Annex III Module B (production)

Certificate Number	HPiVS-iP1020-070-I-01-00		
Date of Issue	04-Nov-2021	Date of Expiry	01-Nov-2031
Manufacturer	Aksa Yangın Söndürme Sistemleri Mühendislik İthalat İhracat San.Tic.Ltd.Şti. Orhan Gazi Mah.1718. Sok.No:18 Esenyurt, İstanbul		
Description of Pressure Equipment	1 kg, 2kg, 4kg, 6kg, 9kg, 12kg, 25kg, 50kg Powder, Foam and Water and Halocarbon Fire Extinguishers		
Drawing No	YS-01 to YS-08 dated 1 Jun 2017		
Representative Specimen Serial No	6Kg: SN 01 to 05, 12kg: SN 01 to 05, 25 kg SN 01.		
Design Pressure (bar)	18 bar		
Design Temperature (°C)	-30 to 60 °C		
Standards Used	EN 3-7:2004+A1:2007, EN 3-8:2006, EN 1866-2:2014		
Report Reference	HPiVS-iP1020-070-DR01; iP1020-070-1		

This Certificate is valid in any European Economic Area Member State.

This Certificate has been issued by **HPi Verification Services (Ireland) Ltd.** which is a body notified to the European Commission according to the provisions of the Pressure Equipment Directive (Notified Body number 2810).

This Certificate is issued following the assessment of a representative sample of the Pressure Equipment detailed above in accordance with the provisions of the above regulations. The equipment must be subject to an appropriate conformity assessment module during manufacture prior to the CE Mark being affixed.

Check this certificate is genuine



Managing Director

Technical Manager



EU Notified Body No. 2810
Company registered in Ireland #577786

© HPI Verification Services (Ireland) Ltd. 2021

Tel +353 (0)1 8017008

Email enquiries@hpivs.ie
www.hpivs.ie

HPi Verification Services (Ireland) Ltd.
Clonross
Dunshaughlin, Co.Meath
A85 XN59, Ireland