

CERTIFICATE OF COMPLIANCE

Certificate Number 20190405-EX28012
Report Reference EX28012-20190329
Issue Date 2019-APRIL-05

Issued to: DUYAR VANA MAKINA SAN VE TIC A S
Osmangazi Mh. 2653 Sk. No:7
34522 Esenyurt Istanbul TURKEY

**This certificate confirms that
representative samples of**

FLOW DETECTION AND TEST ASSEMBLIES
See Addendum for Models

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL Subject 258 Outline of Investigation for Shutoff Valves
for Trim and Drain Purposes

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE


Certificate Number 20190405-EX28012
Report Reference EX28012-20190329
Issue Date 2019-APRIL-05

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models/Product:

Flow detection and Test Assemblies manifolds Y-4070 in sizes 2 through 6 in., rated pressure 300 psi, with grooved ends using The following Listed Components: Listed Model Y-4030 Drain Fitting Special Type manufactured by Duyar, Listed Model VSR Flow Switch Manufactured by Potter Electric, Listed Model IM01 From Shanghai Iron Man Fire Fighting Equipment Company.

Model	Nominal Pipe Size, NPS	Body Material	End Configuration	Rated Pressure, psig
Y-4070	2, 2.5, 3, 4 and 6	DUCTILE IRON	Groove/Groove	300



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

